

大廣有限公司規格承認書


DA KOANG CO., LTD. SPECIFICATION FOR APPROVAL

地址: 台北市內湖區基湖路10巷46號4樓 Add: 4., No. 46, Lane 10, JiHu Road, Taipei, Taiwan

Tel: 886-886-2-8751-5735 Fax: 886-2-2798-8239

E-mail: da.koang@msa.hinet.net Http://www.dakoang.com.tw

品名 ITEM NO.	AGU-G	圖名 MODEL	<b>Ø10.3 x 38.1mm (13/32 x 1-1/2 Inch) Normal Blow Glass Tube Fuses</b>		製圖 DRAWN	校對 DESIGNED BY	核准 APPROVED
版次 REVISION NO.	日期 DATE	改定內容 REVISION	修改者 CHANGE BY	J. L. CHAO	Thomas Lin	James Lin	
1.0	1/13/2009						



Scale: mm

SPECIFICATION:

- ※ Normal Blow Glass Tube Fuses
- ※ 10.30 x 38.1 mm (13/32 x 1-1/2 Inch).
- ※ Caps: Brass with Gold Plating
- ※ Body: Glass Tube
- ※ Element: Zinc Alloy
- ※ Standard: UL & CSA 248-14
- ※ Ampere Rating: 10-100A
- ※ Voltage Rating: 32V DC
- ※ Product do not meet RoHS
- ※ Product not UL Listed.

Part Number	Amp	Part Number	Amp
2096-10A	10A	2096-15A	15A
2096-20A	20A	2096-25A	25A
2096-30A	30A	2096-35A	35A
2096-40A	40A	2096-50A	50A
2096-60A	60A	2096-70A	70A
2096-80A	80A	2096-100A	100A

In	1.0 In	1.35 In	2 In
		Min	Max
10-80A	>4h	1 Hour	30 s

尺寸依據圖示數字 DON'T SCALE DRAWING	單位 UNIT	Mm	一般公差 TOLERANCE CLASS	± 0.2	* 工程承認圖面 *
---------------------------------	------------	----	-------------------------	-------	------------